

Changes to the third edition following August 2007 update

Section Page Amendment

Introduction

Table 1	2	New robust detail E-WM-10 added
Table 3	4-5	New robust detail E-WM-10 added with acceptable combinations
Table 4	6	New robust detail E-WM-10 added

Separating Wall – Masonry

E-WM-1

Detail 8	5	Room-in-roof detail revised to include PUR and PIR forms of rigid insulation
----------	---	--

E-WM-2

Detail 8	5	Room-in-roof detail revised to include PUR and PIR forms of rigid insulation
----------	---	--

E-WM-3

Detail 8	5	Room-in-roof detail revised to include PUR and PIR forms of rigid insulation
----------	---	--

E-WM-4

Detail 8	5	Room-in-roof detail revised to include PUR and PIR forms of rigid insulation
----------	---	--

E-WM-5

Detail 8	5	Room-in-roof detail revised to include PUR and PIR forms of rigid insulation
----------	---	--

E-WM-6

Detail 7	5	Room-in-roof detail revised to include PUR and PIR forms of rigid insulation
----------	---	--

E-WM-8

Detail 8	5	Room-in-roof detail revised to include PUR and PIR forms of rigid insulation
----------	---	--

E-WM-10

All	1-6	New robust detail added - masonry - aircrete thin joint blockwork with specified wall ties (render and gypsum-based board finish)
-----	-----	---

Section Page Amendment

Separating Floor - Timber

E-FT-1

Floor decking	1	Requirements for floor decking clarified as being 15mm thick (min) wood based board, density min. 600 kg/m ³
Checklist	6	Additional note added to 7th checklist item to highlight the importance of ensuring that screws do not touch or penetrate the joists

E-FT-2

Floor decking	1	Requirements for floor decking clarified as being 11mm thick (min) wood based board, density min. 600 kg/m ³ or Walker Timber perforated deck system
Checklist	6	Additional note added to 7th checklist item to highlight the importance of ensuring that screws do not touch or penetrate the joists

E-FT-3

All	1-8	Detail revised to include Gang Nail ecojoist. All permitted metal web joists can now be used in either the top chord/flange or fully built-in condition
Floor decking	1	Requirements for floor decking clarified as being 18mm thick (min) wood based board, density min. 600 kg/m ³
Detail 9	6	Alternative ceiling treatments added
Checklist	8	Additional checklist item added asking which of the permitted metal web joists have been used
Checklist	8	Additional note added to 9th checklist item to highlight the importance of ensuring that screws do not touch or penetrate the joists