CHECKLIST (to be completed by site manager/supervisor)

Company:

Site:

Plot: Site manager/supervisor:

Ref.	Item	Yes (✔)	No (✔)	Inspected (initials & date)
1.	Are wall linings at least 240mm apart?			
2.	Is absorbent material at least 60mm thick?			
3.	Does absorbent material cover whole lining area except above ceiling line in roof void zone?			
4.	Are all joints in wall lining staggered?			
5.	Is separating wall lining correct mass per unit area on both sides?			
6.	Are all joints sealed with tape or caulked with sealant?			
7.	Are services installed in accordance with sketches 9.1 and 9.2?			
8.	If there is a separating floor (e.g. in flats/apartments) has the resilient flanking strip been provided?			
9.	Is separating wall satisfactorily complete?			

Notes (include details of any corrective action)

Site manager/supervisor signature . . . . . .

Copyright in the contents of this handbook is owned by Robust Details Limited. No copying or reproduction of the contents is permitted without the consent of Robust Details Limited with the exception of the checklists. The checklists may be copied and used freely.